


CORRUGATED ALUMINUM PIPE ARCH CULVERTS AND END SECTIONS





5/8" Dia. threaded rod					
Pipe					
size	Length-in.				
18"×11"	14 ³ / ₈				
22"×13"	16				
25"×16"	171/2				
29"×18"	19				
36"×22"	221/4				
43"×27"	25 ³ /8				
50"×31"	281/2				
58"×36"	31 ⁵ /8				


 1^{3} / $_{4}$ " Thread length both ends. 5/8"-11 UNC thread



- 1. End sections shall be made in accordance with specifications M-196

- End sections shall be made in accordance with specifications M-196
 Corner plate shall be the same material and thickness as end section.
 Rivets shall be aluminum alloy 6053-74.
 Threaded rods shall be aluminum alloy 6061-76.
 Side lugs, bolts, and nuts shall be hot-dipped galvanized steel.
 Multiple panel bodies shall have 2" lap seams which are to be tightly joined with 3/8" diameter rivets spaced 6" c. to c.
 Top edge of all end sections to have rolled edge reinforcement (See section A-A).
- 8. Aluminum alloy toe plate required on end sections for pipe arch of 29" rise or larger. Thickness of toe plate to be same as end section. Where toe plate is needed, toe plate, nuts, and bolts are to be included in price bid for end sections.
- 9. Connector section, when specified, shall be corrugated aluminum alloy pipe arch culvert.

 10. Reinforcement for edge of end section shall be alloy 6063-F.
- 11. Connection bands shall conform to AASHTO M-196.



2 2/3" x 1/2" CORRUGATIONS

	ARCH VS I ON	CALV	ΕN	ID SECT	ADDDOV	BODY			
SPAN	RISE	GALV. THICK.	А	В	Н	L	W	APPROX. SLOPE	BODY
IN	IN		ΙN	IN	IN	IN	IN	RATE	PIECE
17	13	0.060	7	9	6	19	30	2 ¹ /2 : 1	1
21	15	0.060	7	10	6	23	36	2 ¹ /2 : 1	1
24	18	0.060	8	12	6	28	42	21/2:1	1
28	20	0.060	9	14	6	32	48	21/2:1	1
35	24	0.075	10	16	6	39	60	21/2:1	1 or 2
42	29	0.075	12	18	8	47	75	21/2:1	1 or 2
49	33	0.105	13	21	9	53	85	21/2:1	2
57	38	0.105	18	26	12	63	90	21/2:1	2
64	43	0.105	18	30	12	70	102	21/4:1	2
* 71	47	0.105	18	33	12	77	114	21/4:1	3


* These sizes have 0.135" thick center panels. Manufacturers tolerances of above dimensions will be allowed.

RIVETED OR HELICAL FABRICATION

2 2/3" BY 1/2" CORRUGATIONS								
		MIN.	MAXIMUM FILL HEIGHT (FEET)					
SPAN	RISE	COVER	FOR METAL THICKNESS					
ΙN	IN	IN	0.060	0.075	0.105	0.135	0.164	
18	11	18	15					
22	13	18	14					
25	16	18	12					
29	18	18	10					
36	22	18	9					
43	27	18		9				
50	31	18			8			
58	36	18				8		
65	40	18				8		
72	44	18					8	

DIA. OF EQUAL			WATER-	LAY	OUT DI	MENSIO	NS
PIPE	SPAN	RISE	WAY	В	Rc	R+	RЬ
IN	ΙN	IN	SQ FT	IN	IN	IN	IN
15	18	11	1.1	41/2	31/2	101/ ₁₆	19 ¹ /8
18	22	13	1.6	43/4	4	11 ⁷ / ₈	371/16
21	25	16	2.2	51 _{/4}	4	12 ³ / ₄	33 ¹ / ₂
24	29	18	2.8	51/2	41/2	14 ³ / ₄	55
30	36	22	4.4	6 ¹ /4	5	18 ¹ / ₄	731/4
36	43	27	6.4	7	51/2	21 ⁹ / ₁₆	91 ⁹ /16
42	50	31	8.7	8	6	25 ¹ /8	971/4
48	58	36	11.4	91/4	7	291/8	115 ¹¹ / ₁₆
54	65	40	14.3	101/2	8	32 ³ / ₄	129 ⁵ ⁄16
60	72	44	17.6	11 ³ / ₄	9	36 ⁵ ⁄16	142 ¹⁵ / ₁₆

		1. 4				
		_				
	NORTH DAKOTA NT OF TRANSPORTATION	This document was				
	10-1-86	originally issued				
	REVISIONS	and sealed by				
DATE CHANGE		MARK S GAYDOS.				
04-28-89 06-25-03 12-01-04	Toe plate note Revised layout PE Stamp added	Registration Number PE-4518, on 12/01/04 and the original document is stored at the Nort Dakota Department of Transportation				



SECTION A-A

Fill height tables are based on the following criteria:

- 1. Embankment weight = 120 lb/ft ³
 2. Max. pipe deflection = 5%
- Bedding Class C Compaction = 95% proctor density Modulus of passive soil resistance
- (E') = 1400 psi HS-20 Live load
- 7. Corner bearing pressure = $2 + \frac{2}{100}$

Connecting band Note #11	
_ If r	necessary, warp inslope to th slope of end section.
	Flow line
Pipe arch	
12"	

 ${^{7}{}_{16}}^{\prime\prime}$ Holes on 12" centers max.

ELEVATION


6" Max.

-Toe plate


6" Max.

See note #8

TYPICAL CROSS SECTION (Showing connector section)



CONNECTING BAND DETAILS FOR HELICAL, WELDED-SEAM CULVERT



PIPE ARCH CULVERT NOTES:

All dimensions are measured from the inside crests of the corrugations.

A tolerance of plus or minus one inch will be permissible in span, rise, and B. The dimension B shall be measured vertically from a horizontal line drawn across the widest portion of the arch.

The lapped longitudinal seams shall be factory riveted and shall be staggered so as to alternate on each side of the center of the top of the arch by approximately fifteen percent of the periphery.

Pipe arch culverts shall conform to the applicable requirements of AASHTO M-196 or M219-66.